



## Water Resources Management Authority

### **BOREHOLE COMPLETION RECORD**

(To be submitted in triplicate)

(Rule 33)

Borehole No:

Borehole Name: **ILPOORI PRIMARY SCHOOL**

Formation: **SEDIMENTARY INTERCALATIONS**

PARTICULARS OF APPLICANT			DETAILS		
1. Full name of applicant(s) (In Block Letters)			<b>ILPOORI PRIMARY SCHOOL</b>		
2. Category of Applicant - Individual, Group [Association, Society], Company, Institution			<b>INSTITUTION</b>		
3. ID Number of Applicant (Individual) or Certificate of Incorporation or Registration for Groups or Companies					
4. PIN Number					
Physical Address where water is to be used (see sketch)			Contact Address of Applicant		
5. L/R Number(s)			6. Box Number	<b>724</b>	
7. Village(s)/Ward(s)	<b>ILPOORI</b>		8. Town	<b>NAROK</b>	
9. Sub-location(s)	<b>MEGWARRA</b>		10. Post Code	<b>20500</b>	
11. Location(s)	<b>SIANA</b>		12. Telephone Contact (Landline)	<b>N/A</b>	
13. Sub-county	<b>NAROK WEST</b>		14. Telephone Contact (Mobile)		
15. County	<b>NAROK</b>		16. Email Contact		
PARTICULARS OF CONTRACTOR			<b>BETTERLINE WATER LTD</b>		
17. Box Number	<b>27277</b>		22. License Number	<b>WDC/30TPQP</b>	
18. Town	<b>NAIROBI</b>		23. Gazetted On	<b>04/08/2022</b>	
19. Post Code	<b>00100</b>		24. Drilling Supervisor	<b>MR. IKUA WAWERU</b>	
20. Telephone Contact (Landline)	<b>0722227397</b>		25. Type and Make of Drill Rig	<b>MAX DRILL 2023</b>	
21. Telephone Contact (Mobile)	<b>0722227397</b>				
22. Email Contact	<b>info@betterlinewater.com</b>				
INTENDED USE OF WATER					
Public W.S.; Irrigation.; Industries.; Domestic.; Stock, other			<b>Domestic</b>		
PARTICULARS OF BOREHOLE					
Type of Borehole: - Drilled; Driven; Bored; Jetted; Other			<b>DRILLED</b>		
Borehole Construction (also see sketch page 3)					
Drilling started (date)	<b>27/12/2024</b>	Drilling completed (date)	<b>28/12/2024</b>	All work completed (date)	<b>16/01/2025</b>
Total Depth: Reported (m)	<b>150</b>	Measured (m)	<b>150</b>	Final (back-filled) Depth (m)	<b>Nil</b>
Hole Diameter (mm)	<b>203</b>	From (m)	<b>0</b>	To (m)	<b>150</b>
Hole Diameter (mm)		From (m)		To (m)	
Hole Diameter (mm)		From (m)		To (m)	
Hole Diameter (mm)		From (m)		To (m)	



<b>Permanent Casing</b>									
<b>Plain</b>									
Type	Mild steel	Diam (mm)	<b>228</b>	Length (m)	<b>1.3</b>	From (m)	<b>0</b>	To (m)	<b>1.3</b>
Type		Diam (mm)	<b>152</b>	Length (m)	<b>96</b>	From (m)	<b>0</b> <b>48</b> <b>60</b> <b>78</b> <b>96</b> <b>108</b> <b>120</b> <b>132</b> <b>144</b>	To (m)	<b>36</b> <b>54</b> <b>72</b> <b>90</b> <b>102</b> <b>114</b> <b>126</b> <b>138</b> <b>150</b>
<b>Slotted or Perforated:</b>			<b>Slotted</b>						
<b>Size and Description of Openings</b>									
Type	Mild steel	Diam (mm)	<b>152</b>	Length (m)	<b>54</b>	From (m)	<b>36</b> <b>54</b> <b>72</b> <b>90</b> <b>102</b> <b>114</b> <b>126</b> <b>138</b>	To (m)	<b>48</b> <b>60</b> <b>78</b> <b>96</b> <b>108</b> <b>120</b> <b>132</b> <b>144</b>
Type		Diam (mm)		Length (m)		From (m)		To (m)	
<b>Screen:</b>									
<b>Type and Make</b>									
Diameter (mm)		Length (m)		Set from (m)		To (m)			
<b>Gravel Pack</b>									
Size of grains (mm)	<b>2-3mm</b>	Roundness (good, fair, poor)	<b>GOOD</b>		Volume inserted in annular Space (m3)	<b>60 BAGS</b>			
		From (m)			To (m)				
<b>Open Hole</b>									
Diam (mm)		From (m)			To (m)				
<b>Aquifer</b>									
1 <sup>st</sup> Water Struck at (m)	<b>36-48</b>		Water Rest Level (m)		<b>18.96</b>				
2 <sup>nd</sup> Water Struck at (m)	<b>90-96</b>		Water Rest Level (m)						
3 <sup>rd</sup> water struck at (m)			Water Rest Level (m)						
Main Aquifer Struck at (m)			Water Rest Level (m)						
Water bearing material	W/fractured trachytes, tuffs	From (m)	<b>36</b>		To (m)	<b>48</b>			
Other Aquifers, Remarks, etc (also see log on page3)			-						
<b>Yield: SWL (m)</b>	<b>18.96m</b>		PWL (m below surface)		<b>136.37m</b>		Discharge (litres per minute)		<b>76.67</b>
After pumping (hours)			<b>24</b>		Recovered to SWL in (minutes)		<b>(60mins)</b>		

The Chief Executive Officer,  
Water Resources Management  
Authority,  
P.O. Box 45250 – 00100  
**NAIROBI**



**Form: WRMA 009 A**  
**Catchment:**  
**WRMA ID:**  
**File:**

Expected production discharge (litres per hour)	<b>4600</b>	With pump set at (m below surface)	<b>138m</b>
---	-------------	------------------------------------	-------------



<i>Pumping Test Record</i> in Summary (Detailed test records on attached sheets): (all depth measurements to be in metres below ground surface)		
	<b>Test No. 1</b>	<b>Test No. 2</b>
Date of Test (day, month, year)	<b>15<sup>th</sup> -16<sup>th</sup> January 2025</b>	
Depth of Borehole at time of test (m)	<b>150m</b>	
Water Entry (perforations or screen setting at time of test)	<b>Refer to page 2</b>	
Static Water (SWL) before test (m)	<b>18.96m</b>	
Type of Pump (Bailler) used	<b>SP 5/60</b>	
Depth of Pump intake (m)	<b>138m</b>	
Discharge (in litres per minute)	<b>76.67l/m</b>	
Pumping Water Level (PWL m)	<b>136.37m</b>	
After pumping continuously for (hours)	<b>24</b>	
Time of Recovery to Original SWL (minutes)	<b>60</b>	
Rate of Recovery-WL after 5 minutes (m)	<b>126.30m</b>	
Rate of Recovery-WL after 20 minutes (m)	<b>88.00m</b>	
Rate of Recovery-WL after 60 minutes (m)	<b>111.07m</b>	
Rate of Recovery-WL after 120 minutes (m)		

(Additional pumping tests to be mentioned in REMARKS and included with file).

Government representative witnessing the test.....

<b>Quality of Water</b>					
Sample (Yes/No)	<b>Clear</b>	Collected at (hour)	<b>1440hrs</b>	On (date)	<b>16/01/2025</b>
Sediment		Taste		Odour	
Colour		Temperature (0c)		Spec. Conductivity (µmho/cm <sup>3</sup> )	

<i>Remarks:</i> (drilling difficulties, gravel-pack details, all pertinent information about the drilling and completion of the hole)	<b>Drilling went on without any challenges</b>
---	--

The Chief Executive Officer,  
Water Resources Management  
Authority,  
P.O. Box 45250 – 00100  
**NAIROBI**



**Form: WRMA 009 A**  
**Catchment:**  
**WRMA ID:**  
**File:**

<i>Drilling Supervisor</i>		<i>Drilling Contractor</i>	
Signature		Signature	
Name	<b>IKUA WAWERU</b>	Name	<b>BETTERLINE WATER LIMITED</b>
Date	<b>17/01/2025</b>	Date	<b>17/01/2025</b>




Borehole No. **C** -

1. *Driller's Log.*

<b>Depth (In Meters)</b>	<b>Resistivity (Ohm)</b>	<b>Formation</b>	<b>Formation Status</b>
0.0 – 1.3	3000	Loamy surficial soils	Dry
1.3 – 8.0	30	Weathered sub-base	Dry
8.0 – 30.0	120	Weathered gneisses	Dry
30.0 – 60.0	90	Highly Fractured gneisses	Moist to wet
60.0 – 200.0	1000	Fractured gneisses	Moist
>200	600	Fractured to fresh gneisses	Wet to dry




## 12. Sketch of Borehole Construction





13. *Location Sketch:* (To be sketched by the driller on the site, showing roads, tracks and prominent land marks, with road distances to the nearest town or trading centre and to water source).



**UTM SITE COORDINATES.**

**UTM 01°33'52.43"S**  
**35°34'13.96"E**





---

---

For Official Use Only

Entered on Schedule..... (Yes/No) Water Sample Received..... (Yes/No)  
Drilling Samples Received ..... (Yes/No) Chemical Analysis Received..... (Yes/No)  
Drilling Samples Filed..... (Yes/No) Geologist's Log Available..... (Yes/No)  
Location Plotted on Maps..... (Yes/No) Hydro geological Report No..... of.....  
(Date)  
Geophysical Curve No..... of.....  
(Date)

Borehole Data entered and checked by (Name)..... Signature.....

**Permit details**

Permit Number ..... Authorised abstraction ..... m<sup>3</sup>/d  
Authorised water use(s) .....  
Pump intake depth ..... m bgl Maximum authorised abstraction rate ..... m<sup>3</sup>/hr

---

All Borehole Completion Records duly completed should be sent to the appropriate WRMA Regional Office.