

BETTERLINE WATER LTD

Water Pumps, Irrigation, Solar Equipment, Generators, Boreholes, Swimming Pools and Water Treatment

Pili Trade Centre, Ground Floor, Godown 7, Opp. Hilton Garden Hotel, Mombasa Road
 Tel: 0759-018376 / 0722-619402 / 0736-948511 / 0735
 P. O. Box 27277-00100, Nairobi
 info@betterlinewater.com
 www.betterlinewater.com

REPORT ON BOREHOLE TEST PUMPING

CLIENT: OSITETI PRIMARY SCHOOL BOREHOLE NAME & LOCATION: NAROK

Testing Contractor: BETTERLINE WATER LIMITED

Compiled by

Laban Nduaru Watari.

Dated: 21th DECEMBER, 2023

CONTENTS

CONTENTS	1
GLOSSARY OF TERMS	2
INTRODUCTION	3
OBJECTIVES	3
CONCEPT	3
Discharge Measurement and Recovery Measurements	3
PROCEDURE	4
Continuous Rate Test (CRT) for 24 Hours	4
Recovery Test Measurements (RTM) After 24 Hours	5
RESULTS AND ANALYSIS	5
Specific Yield/Specific Capacity (24 Hours)	5
Aquifer Transmissivity (T)	6
Analysis of Ground Water Potential	6
CONCLUSIONS	6
RECOMMENDATIONS	6

GLOSSARY OF TERMS

Aquifer: A geological formation or structure, which stores and transmits water and which is able to supply water to wells, boreholes or springs to satisfy a particular water demand.

Aquifer characteristics: Ability of the aquifer to store and transmit ground water

Confined aquifer: Are those aquifers in which the piezometric level is higher than the elevation at which the aquifer was encountered. Static water levels are higher than the top of the formations.

Drawdown: The distance between the static water level and the pumped water level.

Hydro geological: Those factors that deal with subsurface water and related geological aspects of surface water

Pumping Water Level: The level at which water stands in a well when pumping is in progress, this is also called the dynamic water level when measured as measured in the well.

Recharge: General term applied to the passage of water from surface or subsurface sources (e.g. rivers, rainfall, and lateral ground water flow) to the aquifer zones.

Recovery: Return to static water level following abstraction of groundwater.

Residual Drawdown: During water level recovery, the distance between pumped water level and the static water level.

Semi-confined aquifer: An aquifer partially confined by soil layers of low permeability through which recharge and discharge can still occur.

Specific Capacity: Ratio of pumping rate and drawdown (m³/hr/m), a measure of the well performance.

Static Water Level: The level of water in a well that is not affected by abstraction of ground water.

Test Pumping: A test that is conducted to determine aquifer or well characteristics.

Transmissivity: A measure of the aquifer characteristics to conduct water through its saturated thickness (m^2/day)

Well Yield: Is the volume of water per unit of time discharged as litres or cubic metres from a well either by pumping or free flow.

Yield: Volume of water discharge from a well, usually in m³/hr

INTRODUCTION

Getting an adequate supply of safe clean water has a great deal of advantages from ensuring availability of enough quantities by the client for various domestic processes, reducing health risks associated with insufficient water in the upcoming projects, to provision of reliable water.

Taking these into account, the client needing to know the quantity of production from his borehole contracted Test Pumping Unit to carry out a Test Pumping procedure, this is the report.

OBJECTIVES

- 1. To establish the borehole's potential by estimating the sustainable yield and hydraulic performance for water supply.
- 2. To collect a water sample for submission to a reputable laboratory for quality analysis.

CONCEPT


The test pumping consists of pumping the borehole at variable rates and recording the water level (and therefore the drawdown) in the pumping well, the Recovery rate is thereafter recorded with the pump now switched off.

Discharge Measurement and Recovery Measurements

Discharge measurement was done by an approved volumetric method. A calibrated container of 20litres capacity when full was used. When time to fill measurement is made, each discharge measurement is calculated from the average of three-time measurements. Discharge varies by no more than 15% across the constant discharge test. A globe valve was used to control the discharge as the case demanded. **See Discharge Drawdown Test data sheet.**

The recovery test is very useful in qualitatively assessing the pumping effect and possible dewatering of aquifers that may result due to the limited extent of an aquifer. Furthermore, the recovery test will indicate the level to which the aquifer is actually dewatered by measuring the residual drawdown after the borehole is allowed to recover.

PROCEDURE TEST PUMPING CALIBRATION



Continuous Rate Test (CRT) for 24 Hours

16th DECEMBER, 2023.

The team lowered a **Submersible pump SP2-48 Pump** and **1 1/2**" inches GI pipes down to **186m.** The pump was powered by a generator 40KVA. The Static Water Level was measured at **6.90m** before starting the test.

19:37:00 hours: Commenced testing. An average flow of 2.7m³/hr. was recorded during the test with the gate valve fully opened as was with respect to flow.

Recovery Test Measurements (RTM) After 24 Hours

17th DECEMBER 2023.

07:01:00 hours: The RTM begun immediately after the CRT, when the pump was switched off. A total of **87.62%** recovery coefficient was recorded during the 120mins recovery test measurement. This resulted into residual drawdown **3.38m**. **See annexed Recovery data sheet**. The test unit was pulled out thereafter.

RESULTS AND ANALYSIS

Specific Yield/Specific Capacity (24 Hours)

A borehole Specific Capacity (an estimate of borehole transmissibility) is calculated as yield per meter of drawdown.

Using (Driscoll, 1986) formula

Specific capacity S = Q/s

=discharge per hour (m^3/hr) / maximum drawdown (m)= (2.7/76.15)

=0.035456336m³/hr/m

Table 1: Summary of bore hole and test data results

DETAILS/LOCATION	OSITETI BOREHOLE
Date drilled	Refer to drilling records
Measured depth	200m
Water Struck Levels	Refer to drilling records
Date of Test	16 th to17 th December, 2023
Static Water Level (SWL)	6.90m
Pump Intake Depth	186m
Pumping Water Level (PWL)	83.05m
Drawdown	76.15m
Average tested Well Yield	2.7m³/hr.
Duration of Test Pumping	24 Hours
Recovery Time	120mins
Recovery Coefficient	87.62%
Residual Drawdown	3.38
Specific Capacity	0.035456336m ³ /hr/m
Transmissivity	1.038161523m ² /day
Maximum safe design yield (Considering	$1.89m^{3}/hr$.
70% of the average yield)	

Aquifer Transmissivity (T)

It is a measure of the aquifer characteristics to conduct water through its saturated thickness

By using (Logan, 1964) formula,

Transmissivity, T = 1.22 Q/s expressed in m²/day: 1.22 is a constant,

Q is discharge per day and S is drawdown

=1.22 X (2.7 X 24)/76.15

=1.038161523m²/day

Analysis of Ground Water Potential

With a Specific Capacity of **0.035456336m³/hr/m**, an aquifer Transmissivity of **1.038161523m²/day** and a recovery coefficient of **87.62%**, it is conclusive that the borehole is of an excellent recharge potential and is fed mainly from unconfined aquifers. The drilled well depth is assumed to have fully explored all the available upper aquifers in this geological set up.

CONCLUSIONS AND RECOMMENDATIONS

CONCLUSIONS

- 1. With a Specific Capacity of **0.035456336m³/hr/m**, and an aquifer Transmissivity of **1.038161523m²/day**, the borehole is of an excellent recharge potential.
- 2. The drilled depth in this hydro geological setup is assumed to have fully explored all the available upper aquifers in this geological setup.
- 3. The average tested well yield was 2.7m³/hr.

RECOMMENDATIONS

The following recommendations are made

- 1. The Design Yield considering **76.15m** drop from the SWL during abstraction should be a maximum of **1.89m³/hr**.
- 2. Abstraction should <u>not exceed 10 hours a day</u>, since over pumping would lead to the aquifer depletion.
- 3. The drop pipes used for lowering the pump into position should be of either class B GI or UPVC pipes with sufficient tensile strength to withstand the stresses and vibrations associated with pumping water.



BETTERLINE WATER LTD

Water Pumps, Irrigation, Solar Equipment, Generators,
Boreholes, Swimming Pools and Water Treatment

Well No: C
Contract: Borehole Testing Pumping
Client: Ositeti
Location: Narok
Well Type: Drilled
Testing Contractor: Betterline Water Ltd
Static Water Level: 6.90m

Boreholes, Swimming Pools and Water Treatment

*Pili Trade Centre, Ground Floor, Godown 7, Opp. Hillion Garden Hotel, Mombasa Road *Tel: 0799-018376 (1972-619402 / 0736-948511 / 0735-918 376

*P.O. Box 27277-09100, Nairobi *Info@betterflinewater.com *www.betterflinewater.com *w 200m 186m 0.5m SP 2-48 GI 1 1/2" Generator 40 KVA 83.05m

DISCHARGE DRAWDOWN TEST

		Elapsed Time (min)	Water Level (m bdl)	Drawdown (m)	Yield (m3/hr)	EC (uS/cm)	Remarks
16.DECEMBER.2023		0	6.90	0.00			Start of constant discharge test
	19:37:00	1	8.02	1.12			
	19:38:00	2	9.46	2.56	3.20		
	19:39:00	3	10.84	3.94			Blackish
	19:40:00	4	12.44	5.54			
	19:41:00	5	14.44	7.54			
	19:42:00	6	15.50	8.60			
	19:43:00	7	16.24	9.34			
	19:44:00	8	17.24	10.34			
	19:45:00	9	18.25	11.35			
	19:46:00	10	19.37	12.47			
	19:48:00	12	21.22	14.32			
	19:50:00	14	22.19	15.29			
	19:52:00	16	23.56	16.66			
Ī	19:54:00	18	25.03	18.13			Slightly black
Ī	19:56:00	20	26.86	19.96			
Ī	20:01:00	25	31.66	24.76			
Ī	20:06:00	30	34.44	27.54			
ļ	20:11:00	35	37.22	30.32			
	20:16:00	40	40.07	33.17			
	20:21:00	45	43.42	36.52			
	20:26:00	50	45.34	38.44			
	20:31:00	55	47.84	40.94			
	20:36:00	60	49.40	42.50	3.00		Slightly clear
	20:51:00	75	53.59	46.69			, a 2
	21:06:00	90	56.21	49.31			
	21:21:00	105	59.77	52.87			
	21:36:00	120	62.98	56.08			
	22:06:00	150	66.20	59.30			
	22:36:00	180	69.09	62.19			
	23:06:00	210	71.32	64.42			
	23:36:00	240	73.14	66.24	2.70		Clear
	00:36:00	300	75.36	68.46			
	01:36:00	360	76.89	69.99			
ļ	02:36:00	420	77.79	70.89			
ļ.	03:36:00	480	78.80	71.90			
ļ.	04:36:00	540	79.30	72.40			
ļ.	05:36:00	600	79.83	72.93			
ļ.	06:36:00	660	80.19	73.29	2.70		Clear
	07:36:00	720	80.51	73.61			20.000
ļ.	08:36:00	780	80.92	74.02			
ļ.	09:36:00	840	81.02	74.12			
	10:36:00	900	81.28	74.38			
ŀ	11:36:00	960	81.67	74.77			
DECEMBER.2023	12:36:00	1020	81.88	74.98			
	13:36:00	1080	81.92	75.02			
	14:36:00	1140	82.10	75.20			
	15:36:00	1200	82.32	75.42			
ļ.	16:36:00	1260	82.58	75.68			
}	17:36:00	1320	82.78	75.88	2.70		Clear
}	18:36:00	1380	83.04	76.14	2.70		Collected water sample for FCA
H	19:36:00	1380	83.04	76.14			End of 24 hours drawdown tes

Date	Time	Elapsed Time (min)	Water level (m bdl)	Residual Drawdown (m)	Recovery %	Remarks
7.DECEMBER.2023		0	83.05	0.00	0.00%	Start recovery observations
	07:01:00	1	82.80	0.25	0.30%	
	07:02:00	2	81.80	1.25	1.51%	
	07:03:00	3	80.90	2.15	2.59%	
	07:04:00	4	79.71	3.34	4.02%	
	07:05:00	5	78.43	4.62	5.56%	
	07:06:00	6	77.24	5.81	7.00%	
	07:07:00	7	75.76	7.29	8.78%	
	07:08:00	8	74.46	8.59	10.34%	·
	07:09:00	9	73.24	9.81	11.81%	
	07:10:00	10	72.18	10.87	13.09%	
	07:11:00	11	71.02	12.03	14.49%	
	07:12:00	12	69.90	13.15	15.83%	
	07:13:00	13	68.83	14.22	17.12%	
	07:14:00	14	67.28	15.77	18.99%	
	07:15:00	15	65.98	17.07	20.55%	
	07:16:00	16	64.95	18.10	21.79%	
	07:17:00	17	63.79	19.26	23.19%	
	07:18:00	18	62.73	20.32	24.47%	
	07:19:00	19	61.59	21.46	25.84%	
	07:20:00	20	60.89	22.16	26.68%	
	07:22:00	22	58.40	24.65	29.68%	
	07:24:00	24	56.39	26.66	32.10%	
	07:26:00	26	54.40	28.65	34.50%	
	07:28:00	28	52.25	30.80	37.09%	<u> </u>
	07:30:00	30	49.09	33.96	40.89%	
	07:35:00	35	41.09	41.96	50.52%	
	07:40:00	40	38.99	44.06	53.05%	
	07:45:00	45	34.45	48.60	58.52%	
	07:50:00	50	29.40	53.65	64.60%	
	07:55:00	55	26.73	56.32	67.81%	·
	08:00:00	60	24.30	58.75	70.74%	
	09:00:00	120	10.28	72.77	87.62%	
			1			End of 2 hour Recovery